## PLAN MAINTENANCE SYSTEM (PMS)

## **REFRIGERATOR PLAN**

## MAY MONTHLY

CODE	<b>DESCRIPTION</b>	<u>STD</u> <u>R.H</u>	RUNNING HOUR	<u>REMARK</u>
<u>1991.473</u>	Check the operation of the condensing plant	<u>2000</u>	<u>1200</u>	<u>2 MAY 2017</u>
<u>1991.482</u>	<u>Check the operation of all</u> <u>evaporator</u>	<u>2000</u>	<u>1200</u>	<u>2MAY 2017</u>
<u>1991.479</u>	<u>Check that the control</u> <u>equipment operating</u> <u>appropriately</u>	<u>2000</u>	<u>1200</u>	<u>2MAY 2017</u>
<u>1991.465</u>	Check that the refrigerant is dry	<u>2000</u>	<u>1200</u>	<u>2 MAY 2017</u>
1991.470	<u>Check That the power</u> consumsion is in agreement with the operating hours of the compressor	2000 EKA		<u>2 MAY 2017</u>
<u>1991.471</u>	Check that there is no leakage in the plant	<u>4000</u>	1200	<u>15 MAY 2017</u>
<u>1991.472</u>	Inspect possible electric heating (defrosing , discharge, etc)	4000 A R	A N C1200	<u>15 MAY 2017</u>
<u>1991.464</u>	Check that the pipe insulation in intact	4000	<u>1200</u>	<u>15 MAY 2017</u>
<u>1991.482</u>	Check that the door to the cooling room and freezing room shut tight	<u>4000</u>	<u>1200</u>	<u>15 MAY 2017</u>
<u>1991.486</u>	Inspect of all the electrical motors (lubricating)	<u>2000</u>	<u>1200</u>	<u>15 MAY 2017</u>
<u>1991.487</u>	Carry though a complate inspection of the condensors.	<u>4000</u>	<u>1200</u>	<u>15 MAY 2017</u>