

LAMPIRAN 07
LIST OF PORTABLE FIRE EXTINGUISHER

PORTABLE FIRE EXTINGUISHER

MV. VINCA / PANAMA

DATE : 30TH MAY 2017

NO	LOCATION	TYPE	CLASS	EXPIRY	REMARK
1	Wheel house	CO2-6.8Kg	BC	MAY 2020	Last inspection:30/03/17
2	Upper bridge deck passage (F.of Owner)	FM-9 Ltr	AB	MAR 2018	Last inspection:30/03/17
3	Deck Work Shop	DP-5Kg	ABC	MAY 2020	Last inspection:30/03/17
4	Low bridge deck passage (P) (Off/Spare)	FM-9 Ltr	AB	MAR 2018	Last inspection:30/03/17
5	Low bridge deck passage (S) (F.Of C/O)	FM-9 Ltr	AB	MAR 2018	Last inspection:30/03/17
6	Boat deck passage (Mess Room)	FM-9 Ltr	AB	MAR 2018	Last inspection:30/03/17
7	Galley	DP-5Kg	ABC	MAY 2020	Last inspection:30/03/17
8	Entrance E/R boat deck (P) (Changing rm)	FM-9 Ltr	AB	MAR 2018	Last inspection:30/03/17
9	Emergency generator room	DP-5Kg	ABC	MAY 2020	Last inspection:30/03/17
10	Upp. Deck aft (entrance to Eng room)	FM-9 Ltr	AB	MAR 2018	Last inspection:30/03/17
11	Upp. Deck aft (entrance to Eng room)	DP-40Kg	ABC	MAY 2020	Last inspection:30/03/17
12	Upper deck (near boiler)	DP-5Kg	ABC	MAY 2020	Last inspection:30/03/17
13	Upper deck (near boiler)	DP-5Kg	ABC	MAY 2020	Last inspection:30/03/17
14	Upper deck (near boiler)	DP-5Kg	ABC	MAY 2020	Last inspection:30/03/17
15	Upp deck (Air cond room)	DP-5Kg	ABC	MAY 2020	Last inspection:30/03/17
16	Upp deck passage (Ship Office)	FM-9 Ltr	AB	MAR 2018	Last inspection:30/03/17
17	Bosun store (Forcastle)	DP-5Kg	ABC	MAY 2020	Last inspection:30/03/17
18	Bosun store (Forcastle) Foam applicator	FM-20Ltr	AB	JUN 2020	Last inspection:30/03/17
19	E/R 2 nd deck (control room)	CO2-6.8Kg	BC	MAY 2020	Last inspection:30/03/17
20	E/R 2 nd deck (Eng & elect store)	DP-5Kg	ABC	MAY 2020	Last inspection:30/03/17
21	E/R 2 nd deck (Entrance to steering room)	FM-9 Ltr	AB	MAR 2018	Last inspection:30/03/17
22	Steering gear room	CO2-6,8Kg	BC	MAY 2020	Last inspection:30/03/17
23	E/R 2 nd deck (S)	FM-9 Ltr	AB	MAR 2018	Last inspection:30/03/17
24	E/R 2 nd deck forward	FM-9 Ltr	AB	MAR 2018	Last inspection:30/03/17
25	E/R 3 rd deck (Work shop)	FM-9 Ltr	AB	MAR 2018	Last inspection:30/03/17
26	E/R 3 rd deck (near the cyl oil mean tank)	FM-9 Ltr	AB	MAR 2018	Last inspection:30/03/17
27	E/R 3 rd deck (near the L.O purifier)	FM-9 Ltr	AB	MAR 2018	Last inspection:30/03/17
28	E/R 3 rd deck (fwd)	FM-9 Ltr	AB	MAR 2018	Last inspection:30/03/17
29	E/R Floor deck (fwd)	FM-9 Ltr	AB	MAR 2018	Last inspection:30/03/17
30	E/R Floor deck (S)	FM-9 Ltr	AB	MAR 2018	Last inspection:30/03/17
31	Life boat No.1 Stbd	DP-5Kg	ABC	MAY 2020	Last inspection:30/03/17
32	Life boat No.2 port	DP-5Kg	ABC	MAY 2020	Last inspection:30/03/17
33	Galley	CO2-6.8Kg	BC	MAY 2020	Last inspection:30/03/17
34	Deck crane No.1	DP-1.2Kg	ABC	MAY 2020	Last inspection:30/03/17
35	Deck crane No.2	DP-1.2Kg	ABC	MAY 2020	Last inspection:30/03/17

36	Deck crane No.3	DP-1.2Kg	ABC	MAY 2020	Last inspection:30/03/17
37	Deck crane No.4	DP-1.2Kg	ABC	MAY 2020	Last inspection:30/03/17
38	Fire station upp deck (Spare)	CO2-6.8Kg	BC	MAY 2020	Last inspection:30/03/17
39	Fire station upp deck (Spare)	CO2-6.8Kg	BC	MAY 2020	Last inspection:30/03/17
40	Fire station upp deck (Spare)	CO2-6.8Kg	BC	MAY 2020	Last inspection:30/03/17
41	Upper deck (Near Boiler)Foam applicator	FM-20Ltr	AB	JAN 2021	Last inspection:30/03/17
42	E/R Floor deck (fwd)	DP-23Kg	ABC	MAY 2020	Last inspection:30/03/17


PARTICULARS :

1. Total Dry powder chemical (DP) : 17 Cylinder
2. Total CO2 extinguisher (CO2) : 7 Cylinder
3. Total Foam (FM) : 16 Cylinder
4. Total Foam applicator : 2 Unit

Remark : this data will be revised every 3 months/if any item changed/

Last Inspection for LSA FFA Mar 2017 by Yokohama Tsusho, Co. Ltd.

Recharge Foam 04 April 2017 by Ship's Crew



Checked By 3/O: ADOLF AGUSTIN